



Figure 1: Fitting installed upside down



Figure 2: ABS drain valve to be removed and replaced with PVC valve



Figure 3: 2nd ABS drain valve needs to be removed or replaced with PVC



Figure 4: 4 inch to 3 inch reducer in drain line



Figure 5: ABS mixed with PVC, no Vent and illegal pressure fitting, also pictured is the misplaced cleanout in drain line



Figure 7: Drains stacked above each other



Figure 8: Floor cut away under toilet allows toilet to shift



Figure 9: Horizontal venting



Figure 10: Original drain location cut and capped



Figure 11: Sink drain below floor and double trapped



Figure 12: Washer drain not vented